

# **EQUIPMENT SUPPORT - Models SE-GS**

## STANDARD CONSTRUCTION

**SHELL** 

18 gauge galvanized steel

**BASE** 

18 gauge galvanized steel

SUPPORTS

Internal reinforcement @ 18"

**WOOD NAILER** 

3.50" (see schedule)

**FASTENERS** 

Welded Construction

THICKNESS (T)

1-5/8" standard (see schedule)

**MAXIMUM LENGTH** 


120" – larger sizes to be shipped in multiple sections for field assembly.

**FINISH** 

Mill

#### **OPTIONS:**


- Aluminum Construction or Stainless Steel
- Heavier Gauge up 14 gauge galvanized steel
- Prime Coated or Baked / Powder Coat Finish
- Gasket
- Cap
- Insulation



**Model SE-GS** 

## **MODEL SELECTION**

Model	(T) - Thickness
SE-GS-3	3-1/2" - std
SE-GS-5	5-1/2"
SE-G2-7	7-1/2"
SE-GS-9	9-1/2"
SE-GS-11	11-1/2"



DATE	ARCHITECT			CUSTOMER	
PROJECT					
ITEM	QTY	W	Н	DESCRIPTION	



**DEPENDABLE PRODUCTS SINCE 1955** 

# SAFE-AIR OF ILLINOIS INC.

Engineering and General Offices

1855 South 54<sup>th</sup> Avenue, Cicero, Illinois 60804

Phone 708-652-9100 FAX 708-652-9158

www.safeairdowco.com SE-GS -2/07